



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC

155 Center Street, Building C Auburn, Maine 04210

Phone: 207-784-5354 | website: www.allaboratory.com

DATE PRINTED: 09/29/2020

LEAD AND COPPER RESULTS

LAB ID#: 1015

SYSTEM NAME: Sunday River-Jordan Hotel

SYSTEM TOWN: Newry

SAMPLE CATEGORY: Routine Sample

SAMPLING AGENT: Thomas Herling

SAMPLE AGENT #:

RECEIPT TEMP: 21° CELSIUS

SAMPLE LOCATION

Legend	
Passes	✓
Fails EPA Primary	✗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

EPA ID #: ME0094648

WATER SYSTEM TYPE:

TEST UNITS: mg/L ANALYST: JLR-NH

METHOD: Copper EPA 200.8 Lead EPA 200.8

MCL: Copper 1.30 mg/L, Lead 0.015 mg/L

MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L

DATE & TIME RECEIVED: 09/25/2020 10:20AM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
DS-1 DISTRIBUTION SYSTEM, Main Lobby Water Fountain	09/24/2020 8:23AM	2009-03732-001		<0.001	✓		09/28/20	0.185	✓		09/28/20
DS-1 DISTRIBUTION SYSTEM, Men's Spa Bathroom	09/24/2020 8:40AM	2009-03732-002		0.0012	✓		09/28/20	0.106	✓		09/28/20
DS-1 DISTRIBUTION SYSTEM, Hotel Room #166	09/24/2020 8:51AM	2009-03732-003		0.0039	✓		09/28/20	0.153	✓		09/28/20
DS-1 DISTRIBUTION SYSTEM, Crown Room	09/24/2020 9:00AM	2009-03732-004		0.0013	✓		09/28/20	0.165	✓		09/28/20
DS-1 DISTRIBUTION SYSTEM, Hotel Room #301	09/24/2020 9:07AM	2009-03732-005		0.0019	✓		09/28/20	0.221	✓		09/28/20

The results presented in this report relate to the samples listed above in the condition in which they were received.

RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Data Qualifier (DQ) Flags: None

* ME Certified Analysis

Rebecca L. Labranche
Laboratory Director

This analysis meets State of Maine requirements except as noted.

State Certifications: | A & L Laboratory: ME ME00021 | Granite State Analytical Services LLC: NH NH00003 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC