



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Sunday River-Jordan Hotel Condo
Assoc.
PO Box 4500
Newry, ME 04261

Date Printed: 02/05/2024
Work Order #: 2401-04652
Client Job #:
Date Received: 01/30/2024
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director

A & L Laboratory: Accreditations: Maine ME00021, New Hampshire 2501, Maine Radon Registration ID # SPC20
Granite State Analytical Services, LLC: Accreditations: New Hampshire 1015; Maine NH00003;
Massachusetts M-NH0003; Rhode Island 101513; Vermont VT-101507
Nashoba Analytical: Accreditations: Massachusetts M-MA1118



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

DATE PRINTED: 02/05/2024

LEAD AND COPPER RESULTS

LAB ID#: NH00003

SYSTEM NAME: Sunday River-Jordan Hotel Condo Assoc.
SYSTEM TOWN: Newry
SAMPLE CATEGORY: Routine Sample
SAMPLING AGENT: Rick Waltz

SAMPLE AGENT #:
RECEIPT TEMP: 9° CELSIUS

Legend	
Passes	✓
Fails EPA Primary	✗
Fails EPA Secondary	⚠
Fails State Guideline	✗
Attention	⚠

EPA ID#: ME0094648
WATER SYSTEM TYPE:
TEST UNITS: mg/L ANALYST: NM-NH
METHOD: Copper EPA 200.8 Lead EPA 200.8
MCL: Copper 1.3 mg/L, Lead 0.015 mg/L
MDL (RL): Copper 0.001 mg/L, Lead 0.001 mg/L
DATE & TIME RECEIVED: 01/30/2024 03:30PM

SAMPLE LOCATION	DATE/TIME COLLECTED	LABORATORY SAMPLE ID#	CLIENT JOB #	LEAD *	Pass /Fail	DQ	DATE ANALYZED	COPPER *	Pass /Fail	DQ	DATE ANALYZED
DS-1 DISTRIBUTION SYSTEM, Grandavenue 2 Bay Sink	01/26/2024 07:31AM	2401-04652-001		<0.001	✓		02/01/24	0.0969	✓		02/01/24
DS-1 DISTRIBUTION SYSTEM, Sliders Kitchen 2 Bay Sink	01/26/2024 07:36AM	2401-04652-002		<0.001	✓		02/01/24	0.0544	✓		02/01/24
DS-1 DISTRIBUTION SYSTEM, Sliders Bar Handwash Sink	01/26/2024 07:37AM	2401-04652-003		<0.001	✓		02/01/24	0.126	✓		02/01/24
DS-1 DISTRIBUTION SYSTEM, Northern Lights Cafe Handwash	01/26/2024 07:40AM	2401-04652-004		<0.001	✓		02/02/24	0.0562	✓		02/02/24
DS-1 DISTRIBUTION SYSTEM, Room 301 Kitchenette Sink	01/26/2024 07:57AM	2401-04652-005		<0.001	✓		02/02/24	0.111	✓		02/02/24
DS-1 DISTRIBUTION SYSTEM, Room 202 Kitchenette Sink	01/26/2024 07:55AM	2401-04652-006		<0.001	✓		02/01/24	0.0430	✓		02/01/24
DS-1 DISTRIBUTION SYSTEM, Room 266 Kitchenette Sink	01/26/2024 08:02AM	2401-04652-007		<0.001	✓		02/01/24	0.107	✓		02/01/24
DS-1 DISTRIBUTION SYSTEM, Room 272 Kitchenette Sink	01/26/2024 08:08AM	2401-04652-008		<0.001	✓		02/01/24	0.0666	✓		02/01/24
DS-1 DISTRIBUTION SYSTEM, Room 166 Kitchenette Sink	01/26/2024 08:13AM	2401-04652-009		0.0043	✓		02/02/24	0.247	✓		02/02/24
DS-1 DISTRIBUTION SYSTEM, Room 101 Kitchenette Sink	01/26/2024 10:34PM	2401-04652-010		<0.001	✓		02/01/24	0.102	✓		02/01/24

Rebecca L. Labranche
Laboratory Director

♦ Please enclose a copy of this completed form with your sample bottles and may FAX the form to the Drinking Water Program at (207) 287-4172.

STATE OF MAINE DRINKING WATER PROGRAM USE ONLY

TEST RESULTS: (For DWP use only)

90th Percentile, Lead: _____ Note: EPA action level = 0.015 mg/L

90th Percentile, Copper: _____ Note: EPA action level = 1.3 mg/L

2401-04652-001



Sampled: 01/26/24 07:31

ID: Sunday River-Jordan Hotel Condo

PKG-A & L Lead & Copper-First Draw

Samples Collected - Insert Date(s): 1/26/2024

Lab Name: AGL LABORATORY

System Name: TOODAN HOTEL SYSTEM

Address: 27 CADANO LID, NEWRY ME 04261

PWSID#: ME0094648

Number of Samples Required: 10 Compliance Period: 1/1/24 - 6/30/24

Certification of Collection Methods

(Place a ✓ next to each applicable sentence. If the sentence is not applicable, write N/A)

I hereby certify that:

☒ Each first draw tap sample for lead and copper is one liter in volume and was collected after allowing water to stand motionless in the plumbing system for at least six hours.

N/A Each first draw sample collected from a single-family residence has been collected from the cold water kitchen tap or bathroom sink tap.

☒ Each first draw sample collected from a non-residential building has been collected at an interior tap from which water is typically drawn for consumption.

N/A Each first draw sample collected during an annual or 3-year monitoring period has been collected in the months of June, July, August, or September.

N/A Each resident who volunteered to collect tap water samples from his or her home has been instructed in the proper methods for collection of lead and copper samples. I do not challenge the accuracy of those sampling results. Material distributed to residents explaining the proper collection methods, and a list of the residents who performed sampling will be provided upon request by the Drinking Water Program.

Operator Certification

I certify that I have completed both pages of this document. I certify that the information on this form is accurate to the best of my knowledge.

[Signature] 0604514 1/30/24
Signature Operator Number Date

PYCH WATTS WATER DEPARTMENT
Printed Name Title

♦♦NOTE: COMPLETE THE WORKSHEET ON THE SECOND PAGE OF THIS DOCUMENT♦♦

